



TROY TOWNSHIP WATER ASSOCIATION

Public Water Supply ID: IN5262006

Consumer Confidence Report

2024 CCR

Annual Drinking Water Quality Report

TROY TOWNSHIP WATER ASSOCIATION

Public Water System ID: IN5262006

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2024. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien).

For more information regarding this report, contact:
Jackie Hilgartner (812) 836-2100

Or you can join us at our Water Board Meetings, which are held regularly on Tuesday following second Monday of each month at Troy Township Water Association Office located at 14100 Old State Road 37, Tell City, IN 47586 at 9:00 a.m. We encourage you to participate and give us your feedback.

Sources of Drinking Water

TROY TOWNSHIP WATER ASSOCIATION is Purchased ground water.

Our water source(s) and source water assessment information are listed below:

Source Name	Type of Water	Report Status	Location
TELL CITY- 5262004	Ground water		

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Lead Service Line Inventory:

The Lead and Copper Rule (LCR) now mandates us to make our Service Line Inventory available to the public. If you are interested in viewing our Service Line Inventory, you can use the following link: <https://pws-ptd.120wateraudit.com/TroyTownshipWaterAssoc-IN>

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg: Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

LRAA: Locational Running Annual Average

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Our water system tested a minimum of 1 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	Highest RAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2024	1	ppm	0.4 - 0.9	4	4	Water additive used to control microbes

Unregulated Contaminants

Our system collected samples under the U.S. EPA Unregulated Contaminants Monitoring Rule (UCMR) for 29 PFAS compounds and Lithium. This monitoring is being conducted so the EPA can receive occurrence data for these compounds to determine what additional compounds may need to be regulated in drinking water. We collected samples in September 2022 and July 2023 and detected the compounds shown in this table. These compounds are not regulated at this time. If you would like to review our results, contact our office at (812) 836-2100.

Unregulated Contaminant Monitoring Rule (UCMR)	Collection Date of HV	Highest Value (HV)	Range of Sampled Result(s)	Unit
Perfluorooctanoic acid (PFOA) (voluntary sampling)	9/22/22	3.2	NA	ng/L
Perfluorooctanoic acid (PFOA) (IDEM Tested)	7/11/23	3.5	NA	ng/L

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2024	0.0894	0.00688 - 0.622	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2024	2.75	2.75 - 3.16	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Lead Service Line Availability

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	ROCKY POINT PUMPHOUSE	2023 - 2024	2	1.76 - 1.76	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	WATER TANK #1 - SUGAR MAPLE RD	2023 - 2024	1	1.03 - 1.03	ppb	60	0	By-product of drinking water disinfection
TTHM	ROCKY POINT PUMPHOUSE	2023 - 2024	31	31 - 31	ppb	80	0	By-product of drinking water chlorination
TTHM	WATER TANK #1 - SUGAR MAPLE RD	2023 - 2024	28	28 - 28	ppb	80	0	By-product of drinking water chlorination

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
------------------	---------	----------------	-----------------------

No violations during this period.

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Deficiencies

Unresolved significant deficiencies that were identified during a survey done on the water system are shown below.

Date Identified	Facility	Code	Activity	Due Date	Description
7/23/2020	DISTRIBUTION SYSTEM	DS07		2/25/2025	System does not have a cross-connection policy in effect

Tell City Water Department (Reseller) Contaminants

Regulated Contaminants	Collection Date	Water System	Highest Sample Result	Range of Sampled Result(s) (low - high)	Unit	MCL	MCLG	Typical Source
BARIUM	3/6/2023	TELL CITY WATER DEPARTMENT	0.0744	0.0744	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	3/6/2023	TELL CITY WATER DEPARTMENT	0.543	0.543	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE-NITRITE	5/3/2021	TELL CITY WATER DEPARTMENT	2.47	2.47	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Water System	Highest LRAA	Range of Sampled Result(s) (low - high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2023 - 2024	TELL CITY WATER DEPARTMENT	2	2.13	ppb	60	0	By-product of drinking water disinfection
TTHM	2023 - 2024	TELL CITY WATER DEPARTMENT	36	36	ppb	80	0	By-product of drinking water chlorination

Water System Name	Determination Date	Deficiency Description	Comments
-------------------	--------------------	------------------------	----------

There are no additional required health effects notices from Purchases.

Tell City Water Department (Reseller) Violations and Health Effects Information

During the 2024 calendar year, the water system(s) that we purchase water from had the below noted violation(s) of drinking water regulations.

Water System	Type	Category	Analyte	Compliance Period
IN5262004	LEAD CONSUMER NOTICE (LCR)	RPT	LEAD & COPPER RULE	12/31/2020 - 1/16/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	XYLENES, TOTAL	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	VINYL CHLORIDE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	TRICHLOROETHYLENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	TRANS-1,2-DICHLOROETHYLENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	TOLUENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	TETRACHLOROETHYLENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	STYRENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	P-DICHLOROBENZENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	O-DICHLOROBENZENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	ETHYLBENZENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	DICHLOROMETHANE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	CIS-1,2-DICHLOROETHYLENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	CHLOROBENZENE	12/31/2023 - 3/30/2024

IN5262004	MONITORING, ROUTINE MINOR	MON	CARBON TETRACHLORIDE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	BENZENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,2-DICHLOROPROPANE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,2-DICHLOROETHANE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,2,4- TRICHLOROBENZENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,1-DICHLOROETHYLENE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,1,2-TRICHLOROETHANE	12/31/2023 - 3/30/2024
IN5262004	MONITORING, ROUTINE MINOR	MON	1,1,1-TRICHLOROETHANE	12/31/2023 - 3/30/2024

There are no additional required health effects violation notices from Purchases.